

2008 Annual Drinking Water Quality Report Town of Holden Beach

PWS ID# 04-10-060

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a review of last year's water quality. Included are details about the source your water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Mr. Chris Clemmons, Public Works Director with the Town of Holden Beach at 910-842-6488. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at the Holden Beach Town Hall at 110 Rothschild Street on the 2nd Tuesday of each month at 7:00PM.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is from two different sources. The Northeast Cape Fear River above Lock & Dam # 1, and ground water from 15 different wells that are obtaining water from the Castle Hayne Aquifer.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Town of Holden Beach (Brunswick County) was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Wells # 1-15	Moderate	March 30, 2009
Northeast Cape Fear River	Moderate	March 30, 2009

The complete SWAP Assessment report for the Town of Holden Beach (Brunswick County) may be viewed on the Web at: <http://www.deh.enr.state.nc.us/pws/swap> Please note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncmail.net. Please indicate your system name, PWSID, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-715-2633.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the systems’ potential to become contaminated by PCS’s in the assessment area.

Violations that Your Water System Received for the Report Year

During 2008, our water system had no violations, as our water met or exceeded the requirements mandated by the Public Water Supply Branch of the Department of Environment and Natural Resources.

Water Quality Data Table of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31,2008.** The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Important Drinking Water Definitions:

Not-Applicable (N/A) – Information not applicable/not required for that particular water system or for that particular rule.

Non-Detects (ND) - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfection Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfection Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Extra Note: MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Microbiological Contaminants (Holden Beach)

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	Y	N/D	1	one positive monthly sample	Naturally present in the environment
Fecal Coliform or E. coli (presence or absence)	N	N/D	0	0 (Note: The MCL is exceeded if a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive)	Human and animal fecal waste

Turbidity* - Systems with population $\geq 10,000$ (Brunswick County Result)

Contaminant (units)	MCL Violation Y/N	Your Water Avg.	MCLG	MCL	Likely Source of Contamination
Turbidity (NTU)	N	0.028 ntu	N/A	TT = 1 NTU	Soil runoff
		100 %		TT = percentage of samples ≤ 0.3 NTU	

* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Inorganic Contaminants (Brunswick County)

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Fluoride (ppm)	2008	N	0.94 ppm	N/A		4ppm	4ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Nitrate/Nitrite Contaminants (Brunswick County)

Contaminant (units)	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
			Low	High			
Nitrate (as Nitrogen) (ppm)	N	N/D	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Unregulated Inorganic Contaminants (Brunswick County)

Contaminant (units)	Sample Date	Your Water	Range		Secondary MCL
			Low	High	
Sulfate (ppm)	2008	13.6 ppm	N/A		250

Unregulated VOC Contaminants (Brunswick County)

Contaminant (units)	Sample Date	Your Water	Range	
			Low	High
Chloroform (ppb)	2007	6.0 ppb	N/A	
Bromodichloromethane (ppb)	2007	6.9 ppb	N/A	
Bromoform (ppb)	2007	1.3 ppb	N/A	
Chlorodibromomethane (ppb)	2007	8.1 ppb	N/A	

Lead and Copper Contaminants (Town of Holden Beach)

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	9-10-07	0.082 ppm	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb) (90 th percentile)	9-10-07	7 ppb	0	0	AL=15 ppb	Corrosion of household plumbing systems, erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Holden Beach is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Radioactive Contaminants (Brunswick County Results)

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Beta/photon emitters (pCi/L)	2007	N	2.48 pCi/l	0	50 pCi/l *	Decay of natural and man-made deposits

* Note: The MCL for beta particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

Disinfection Byproduct Precursors Contaminants (Holden Beach Results)

Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	N	49.9	35.7-60.8	N/A	TT	Naturally present in the environment	ACC 4

Note: Depending on the TOC in our source water, the system MUST have a certain % removal of TOC or must achieve alternative compliance criteria. If we do not achieve that % removal, there is an alternative % removal. If we fail to meet the alternative % removal, we are in violation of a Treatment Technique.

Disinfectants and Disinfection Byproducts Contaminants (Holden Beach and Brunswick County Results)

Contaminant (units)	MCL/MRDL Violation Y/N	Your Water (AVG)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb) [Total Trihalomethanes]	N	19 ppb	10-48 ppb	N/A	80 ppb	By-product of drinking water chlorination
HAA5 (ppb) [Total Haloacetic Acids]	N	22 ppb	18-28 ppb	N/A	60 ppb	By-product of drinking water disinfection
Chlorite (ppm)	N	0.78 ppm	.06-1.0 ppm	0.8	1	By-product of drinking water chlorination
Chlorine dioxide (ppb)	N	0.02 ppm	ND-0.32 ppm	MRDLG = 800	MRDL = 800	Water additive used to control microbes
Chloramines (ppm)	N	2.59 ppm	1.60-3.10 ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes
Chlorine (ppm)	N	2.0 ppm	1.67-2.11 ppm	MRDLG = 4ppm	MRDL = 4 ppm	Water additive used to control microbes

Secondary Contaminants, required by the NC Public Water Supply Section, are substances that affect the taste, odor, and/or color of drinking water. These aesthetic contaminants normally do not have any health effects and normally do not affect the safety of your water.

Water Characteristics Contaminants (Brunswick County)

Contaminant (units)	Sample Date	Your Water	Range Low/High	Secondary MCL
Sodium (ppm)	2008	19.1 ppm	N/A	N/A

Consumer Confidence Report Certification Form

Water System Name: _____

PWS ID#: ____ - ____ - ____ - ____ Report Year: _____ Population Served: _____

The community water system (CWS) named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory.

Certified by: Name: _____ Title: _____

Signature: _____

Phone #: _____ Date: _____

Check methods used and complete:

____ Systems serving 100,000 or more persons must post the CCR on a publicly-accessible Internet site which is www. _____

____ Systems serving 10,000 or more persons must distribute the CCR by mail or direct delivery.
Date Delivered: _____ and specify direct delivery methods: _____

____ Systems serving less than 10,000 persons but more than 500 persons must either distribute the CCR by mail or direct delivery. Date Delivered: _____ and specify direct delivery method: _____

OR (mailing waiver option of the CCR itself) (*Voided if using CCR for Tier III Public Notification!*)

____ notify by "direct means" that the CCR is not being mailed, but it will be published in what newspaper(s) and when (attach copy of notice)
Date Delivered: _____ and specify "direct means" of delivery of the notice: _____

____ and the complete CCR was printed in the local newspaper(s)
____ and a copy of the CCR was made available upon request

____ Systems serving 500 or fewer persons must either distribute the CCR by mail or direct delivery.
Date Delivered: _____ and specify direct delivery methods: _____

OR (mailing waiver option of the CCR itself) (*Voided if using CCR for Tier III Public Notification!*)

____ notify by "direct means" that the CCR is not being mailed, but how a copy may be obtained (attach copy of notice)
Date Delivered: _____ and specify "direct means" of delivery of the notice: _____

____ and a copy of the CCR was made available upon request

____ "Good faith" efforts (in addition to the above required methods) were used to reach non-bill paying consumers

such as industry employees, apartment tenants, etc. Those extra efforts included the following methods:

- ____ posting the CCR on the Internet at www. _____
- ____ mailing the CCR to postal patrons within the service area
- ____ advertising the availability of the CCR in news media (attach copy of announcement)
- ____ publication of the CCR in local newspaper (attach copy)
- ____ posting the CCR in public places such as:(attach list if needed) _____

____ delivery of multiple copies to single bill addresses serving several persons such as: apartments,
businesses, and large private employers
____ delivery to community organizations such as: (attach list if needed) _____

Note: For the mailing waiver option, the Direct Means allowed are a letter, a bill stuffer, a door hanger, or a postcard dedicated to the CCR.
The notice may not be on the water bill itself as the only means of notification.